**********
23 Sep 2013 (1215-0015 UT) OPERATOR: mcb
WEATHER INFO: Winds-> 5.7 mph @ 116, 11.6 C, 45.3% RH, 607.4 Torr, clear

1. Tom, Mike and Joe are on site.
2. Joe brought up some more conduit and lumber.
3. We continued work on phase 2 of the rebar.
4. We continued work on the conduit.
5. Chris Gilmore and Brant Dunaway of UA Facilities Management came and replaced the Rheem Air Conditioner’s compressor. The control-room AC is back in service.

**********
23 Sep 2013 (0015-1215 UT) OPERATOR:
WEATHER INFO: Winds-> 0.4 mph @ 225, 28.0 C, 29.8% RH, 610.8 Torr